

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE



**Low-voltage switchgear and controlgear assemblies –  
Part 1: General rules**

**Ensembles d'appareillage à basse tension –  
Partie 1: Règles générales**



## THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2011 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland  
Email: [inmail@iec.ch](mailto:inmail@iec.ch)  
Web: [www.iec.ch](http://www.iec.ch)

### About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

### About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

▪ Catalogue of IEC publications: [www.iec.ch/searchpub](http://www.iec.ch/searchpub)

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

▪ IEC Just Published: [www.iec.ch/online\\_news/justpub](http://www.iec.ch/online_news/justpub)

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

▪ Electropedia: [www.electropedia.org](http://www.electropedia.org)

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

▪ Customer Service Centre: [www.iec.ch/webstore/custserv](http://www.iec.ch/webstore/custserv)

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: [csc@iec.ch](mailto:csc@iec.ch)  
Tel.: +41 22 919 02 11  
Fax: +41 22 919 03 00

### A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

### A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

▪ Catalogue des publications de la CEI: [www.iec.ch/searchpub/cur\\_fut-f.htm](http://www.iec.ch/searchpub/cur_fut-f.htm)

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

▪ Just Published CEI: [www.iec.ch/online\\_news/justpub](http://www.iec.ch/online_news/justpub)

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

▪ Electropedia: [www.electropedia.org](http://www.electropedia.org)

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

▪ Service Clients: [www.iec.ch/webstore/custserv/custserv\\_entry-f.htm](http://www.iec.ch/webstore/custserv/custserv_entry-f.htm)

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: [csc@iec.ch](mailto:csc@iec.ch)  
Tél.: +41 22 919 02 11  
Fax: +41 22 919 03 00



IEC 61439-1

Edition 2.0 2011-08

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE



**Low-voltage switchgear and controlgear assemblies –  
Part 1: General rules**

**Ensembles d'appareillage à basse tension –  
Partie 1: Règles générales**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

PRICE CODE XG  
CODE PRIX

ICS 29.130.20

ISBN 978-2-88912-634-7

## CONTENTS

FOREWORD.....	8
INTRODUCTION.....	11
1 Scope.....	12
2 Normative references .....	12
3 Terms and definitions .....	15
3.1 General terms .....	15
3.2 Constructional units of ASSEMBLIES .....	17
3.3 External design of ASSEMBLIES .....	18
3.4 Structural parts of ASSEMBLIES .....	18
3.5 Conditions of installation of ASSEMBLIES.....	20
3.6 Insulation characteristics.....	20
3.7 Protection against electric shock .....	23
3.8 Characteristics .....	25
3.9 Verification .....	27
3.10 Manufacturer/user .....	28
4 Symbols and abbreviations.....	28
5 Interface characteristics .....	29
5.1 General .....	29
5.2 Voltage ratings .....	29
5.2.1 Rated voltage ( $U_n$ ) (of the ASSEMBLY) .....	29
5.2.2 Rated operational voltage ( $U_e$ ) (of a circuit of an ASSEMBLY).....	29
5.2.3 Rated insulation voltage ( $U_i$ ) (of a circuit of an ASSEMBLY) .....	29
5.2.4 Rated impulse withstand voltage ( $U_{imp}$ ) (of the ASSEMBLY).....	29
5.3 Current ratings .....	30
5.3.1 Rated current of the ASSEMBLY ( $I_{nA}$ ) .....	30
5.3.2 Rated current of a circuit ( $I_{nC}$ ) .....	30
5.3.3 Rated peak withstand current ( $I_{pk}$ ).....	30
5.3.4 Rated short-time withstand current ( $I_{CW}$ ) (of a circuit of an ASSEMBLY) .....	30
5.3.5 Rated conditional short-circuit current of an ASSEMBLY ( $I_{CC}$ ).....	30
5.4 Rated diversity factor (RDF) .....	31
5.5 Rated frequency ( $f_n$ ).....	31
5.6 Other characteristics .....	31
6 Information .....	32
6.1 ASSEMBLY designation marking .....	32
6.2 Documentation .....	32
6.2.1 Information relating to the ASSEMBLY .....	32
6.2.2 Instructions for handling, installation, operation and maintenance .....	32
6.3 Device and/or component identification .....	33
7 Service conditions .....	33
7.1 Normal service conditions .....	33
7.1.1 Ambient air temperature .....	33
7.1.2 Humidity conditions .....	33
7.1.3 Pollution degree .....	33
7.1.4 Altitude.....	34
7.2 Special service conditions .....	34
7.3 Conditions during transport, storage and installation .....	35

8	Constructional requirements .....	35
8.1	Strength of materials and parts.....	35
8.1.1	General .....	35
8.1.2	Protection against corrosion .....	35
8.1.3	Properties of insulating materials.....	35
8.1.4	Resistance to ultra-violet radiation.....	36
8.1.5	Mechanical strength .....	36
8.1.6	Lifting provision .....	36
8.2	Degree of protection provided by an ASSEMBLY enclosure.....	36
8.2.1	Protection against mechanical impact.....	36
8.2.2	Protection against contact with live parts, ingress of solid foreign bodies and water .....	36
8.2.3	ASSEMBLY with removable parts .....	37
8.3	Clearances and creepage distances .....	37
8.3.1	General .....	37
8.3.2	Clearances .....	38
8.3.3	Creepage distances.....	38
8.4	Protection against electric shock .....	39
8.4.1	General .....	39
8.4.2	Basic protection.....	39
8.4.3	Fault protection .....	40
8.4.4	Protection by total insulation.....	42
8.4.5	Limitation of steady-state touch current and charge.....	43
8.4.6	Operating and servicing conditions .....	43
8.5	Incorporation of switching devices and components .....	45
8.5.1	Fixed parts .....	45
8.5.2	Removable parts .....	45
8.5.3	Selection of switching devices and components.....	46
8.5.4	Installation of switching devices and components .....	46
8.5.5	Accessibility .....	46
8.5.6	Barriers .....	47
8.5.7	Direction of operation and indication of switching positions.....	47
8.5.8	Indicator lights and push-buttons .....	47
8.6	Internal electrical circuits and connections .....	47
8.6.1	Main circuits .....	47
8.6.2	Auxiliary circuits .....	48
8.6.3	Bare and insulated conductors .....	48
8.6.4	Selection and installation of non-protected live conductors to reduce the possibility of short-circuits .....	49
8.6.5	Identification of the conductors of main and auxiliary circuits.....	49
8.6.6	Identification of the protective conductor (PE, PEN) and of the neutral conductor (N) of the main circuits .....	49
8.7	Cooling.....	49
8.8	Terminals for external conductors.....	49
9	Performance requirements .....	51
9.1	Dielectric properties .....	51
9.1.1	General .....	51
9.1.2	Power-frequency withstand voltage .....	51
9.1.3	Impulse withstand voltage .....	51

9.1.4	Protection of surge protective devices .....	51
9.2	Temperature rise limits .....	52
9.3	Short-circuit protection and short-circuit withstand strength .....	52
9.3.1	General .....	52
9.3.2	Information concerning short-circuit withstand strength .....	52
9.3.3	Relationship between peak current and short-time current.....	53
9.3.4	Co-ordination of protective devices .....	53
9.4	Electromagnetic compatibility (EMC) .....	53
10	Design verification .....	54
10.1	General .....	54
10.2	Strength of materials and parts.....	55
10.2.1	General .....	55
10.2.2	Resistance to corrosion .....	55
10.2.3	Properties of insulating materials.....	56
10.2.4	Resistance to ultra-violet (UV) radiation.....	58
10.2.5	Lifting .....	58
10.2.6	Mechanical impact.....	59
10.2.7	Marking .....	59
10.3	Degree of protection of ASSEMBLIES .....	59
10.4	Clearances and creepage distances .....	59
10.5	Protection against electric shock and integrity of protective circuits .....	60
10.5.1	Effectiveness of the protective circuit.....	60
10.5.2	Effective earth continuity between the exposed conductive parts of the ASSEMBLY and the protective circuit.....	60
10.5.3	Short-circuit withstand strength of the protective circuit .....	60
10.6	Incorporation of switching devices and components .....	61
10.6.1	General .....	61
10.6.2	Electromagnetic compatibility .....	61
10.7	Internal electrical circuits and connections .....	61
10.8	Terminals for external conductors.....	61
10.9	Dielectric properties .....	61
10.9.1	General .....	61
10.9.2	Power-frequency withstand voltage .....	61
10.9.3	Impulse withstand voltage .....	62
10.9.4	Testing of enclosures made of insulating material.....	64
10.9.5	External operating handles of insulating material.....	64
10.10	Verification of temperature rise.....	64
10.10.1	General .....	64
10.10.2	Verification by testing .....	64
10.10.3	Derivation of ratings for similar variants.....	70
10.10.4	Verification assessment.....	71
10.11	Short-circuit withstand strength .....	74
10.11.1	General .....	74
10.11.2	Circuits of ASSEMBLIES which are exempted from the verification of the short-circuit withstand strength .....	74
10.11.3	Verification by comparison with a reference design – Utilising a check list .....	75
10.11.4	Verification by comparison with a reference design – Utilising calculation .....	75
10.11.5	Verification by test.....	75

10.12	Electromagnetic compatibility (EMC)	80
10.13	Mechanical operation	80
11	Routine verification	80
11.1	General	80
11.2	Degree of protection of enclosures	81
11.3	Clearances and creepage distances	81
11.4	Protection against electric shock and integrity of protective circuits	81
11.5	Incorporation of built-in components	81
11.6	Internal electrical circuits and connections	81
11.7	Terminals for external conductors	81
11.8	Mechanical operation	82
11.9	Dielectric properties	82
11.10	Wiring, operational performance and function	82
Annex A (normative)	Minimum and maximum cross-section of copper conductors suitable for connection to terminals for external conductors (see 8.8)	90
Annex B (normative)	Method of calculating the cross-sectional area of protective conductors with regard to thermal stresses due to currents of short duration	91
Annex C (informative)	User information template	92
Annex D (informative)	Design verification	96
Annex E (informative)	Rated diversity factor	97
Annex F (normative)	Measurement of clearances and creepage distances	106
Annex G (normative)	Correlation between the nominal voltage of the supply system and the rated impulse withstand voltage of the equipment	111
Annex H (informative)	Operating current and power loss of copper conductors	113
Annex I (Void)		115
Annex J (normative)	Electromagnetic compatibility (EMC)	116
Annex K (normative)	Protection by electrical separation	123
Annex L (informative)	Clearances and creepage distances for North American region	126
Annex M (informative)	North American temperature rise limits	127
Annex N (normative)	Operating current and power loss of bare copper bars	128
Annex O (informative)	Guidance on temperature rise verification	130
Annex P (normative)	Verification of the short-circuit withstand strength of busbar structures by comparison with a tested reference design by calculation	135
	Bibliography	139
	Figure E.1 – Typical ASSEMBLY	98
	Figure E.2 – Example 1: Table E.1 – Functional unit loading for an ASSEMBLY with a rated diversity factor of 0,8	100
	Figure E.3 – Example 2: Table E.1 – Functional unit loading for an ASSEMBLY with a rated diversity factor of 0,8	101
	Figure E.4 – Example 3: Table E.1 – Functional unit loading for an ASSEMBLY with a rated diversity factor of 0,8	102
	Figure E.5 – Example 4: Table E.1 – Functional unit loading for an ASSEMBLY with a rated diversity factor of 0,8	103
	Figure E.6 – Example of average heating effect calculation	104
	Figure E.7 – Example graph for the relation between the equivalent RDF and the parameters at intermittent duty at $t_1 = 0,5$ s, $I_1 = 7 \cdot I_2$ at different cycle times	105

Figure E.8 – Example graph for the relation between the equivalent RDF and the parameters at intermittent duty at $I_1 = I_2$ (no starting overcurrent).....	105
Figure F.1 – Measurement of ribs .....	110
Figure J.1 – Examples of ports .....	116
Figure O.1 – Temperature rise verification methods .....	134
Figure P.1 – Tested busbar structure (TS) .....	135
Figure P.2 – Non tested busbar structure (NTS).....	136
Figure P.3 – Angular busbar configuration with supports at the corners .....	138
Table 1 – Minimum clearances in air <sup>a</sup> (8.3.2).....	82
Table 2 – Minimum creepage distances (8.3.3) .....	83
Table 3 – Cross-sectional area of a copper protective conductor (8.4.3.2.2) .....	83
Table 4 – Conductor selection and installation requirements (8.6.4).....	84
Table 5 – Minimum terminal capacity for copper protective conductors (PE, PEN) (8.8) .....	84
Table 6 – Temperature-rise limits (9.2) .....	85
Table 7 – Values for the factor $n$ <sup>a</sup> (9.3.3) .....	86
Table 8 – Power-frequency withstand voltage for main circuits (10.9.2) .....	86
Table 9 – Power-frequency withstand voltage for auxiliary and control circuits (10.9.2).....	86
Table 10 – Impulse withstand test voltages (10.9.3).....	87
Table 11 – Copper test conductors for rated currents up to 400 A inclusive (10.10.2.3.2) .....	87
Table 12 – Copper test conductors for rated currents from 400 A to 4 000 A (10.10.2.3.2) .....	88
Table 13 – Short-circuit verification by comparison with a reference design: check list (10.5.3.3, 10.11.3 and 10.11.4).....	88
Table 14 – Relationship between prospective fault current and diameter of copper wire .....	89
Table A.1 – Cross-section of copper conductors suitable for connection to terminals for external conductors .....	90
Table B.1 – Values of $k$ for insulated protective conductors not incorporated in cables, or bare protective conductors in contact with cable covering.....	91
Table C.1 – Template .....	92
Table D.1 – List of design verifications to be performed .....	96
Table E.1 – Examples of loading for an ASSEMBLY with a rated diversity factor of 0,8 .....	99
Table E.2 – Example of loading of a group of circuits (Section B – Figure E.1) with a rated diversity factor of 0,9 .....	104
Table E.3 – Example of loading of a group of circuits (Sub-distribution board – Figure E.1) with a rated diversity factor of 0,9.....	104
Table F.1 – Minimum width of grooves .....	106
Table G.1 – Correspondence between the nominal voltage of the supply system and the equipment rated impulse withstand voltage .....	112
Table H.1 – Operating current and power loss of single-core copper cables with a permissible conductor temperature of 70 °C (ambient temperature inside the ASSEMBLY: 55 °C) .....	113
Table H.2 – Reduction factor $k_1$ for cables with a permissible conductor temperature of 70 °C (extract from IEC 60364-5-52:2009, Table B.52.14).....	114
Table J.1 – Tests for EMC immunity for environment A (see J.10.12.1).....	120
Table J.2 – Tests for EMC immunity for environment B (see J.10.12.1).....	121



Table J.3 – Acceptance criteria when electromagnetic disturbances are present.....	122
Table K.1 – Maximum disconnecting times for TN systems .....	125
Table L.1 – Minimum clearances in air .....	126
Table L.2 – Minimum creepage distances .....	126
Table M.1 – North American temperature rise limits .....	127
Table N.1 – Operating current and power loss of bare copper bars with rectangular cross-section, run horizontally and arranged with their largest face vertical, frequency 50 Hz to 60 Hz (ambient temperature inside the ASSEMBLY: 55 °C, temperature of the conductor 70 °C).....	128
Table N.2 – Factor $k_4$ for different temperatures of the air inside the ASSEMBLY and/or for the conductors .....	129

# INTERNATIONAL ELECTROTECHNICAL COMMISSION

## LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR ASSEMBLIES –

### Part 1: General rules

#### FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61439-1 has been prepared by subcommittee 17D: Low-voltage switchgear and controlgear assemblies, of IEC technical committee 17: Switchgear and controlgear.

This second edition cancels and replaces the first edition published in 2009. It constitutes a technical revision.

This second edition includes the following significant technical changes with respect to the last edition of IEC 61439-1:

- revision of service conditions in Clause 7;
- numerous changes regarding verification methods in Clause 10;
- modification of routine verification in respect of clearances and creepage distances (see 11.3);